

京都市告示第 2 4 5号

特定都市河川浸水被害対策法施行令（平成 1 6 年政令第 1 6 8 号）第 9 条第 2 項及び特定都市河川浸水被害対策法施行規則（平成 1 6 年省令第 6 4 号）第 2 1 条第 1 項の規定により、国土交通省告示第 4 7 2 号で指定された特定都市河川流域における基準降雨を別紙のとおり定める。

令和 7 年 6 月 2 0 日

京都市長 松 井 孝 治

別紙

降雨波形 : 中央集中型
 生起確率 : 10年につき1回の割合
 24時間総雨量 : 193.4 mm/h
 最大降雨強度 (1時間) : 57.5 mm/h
 最大降雨強度 (10分間) : 122.7 mm/h

時	分	降雨基準値 (mm/h)	時	分	降雨基準値 (mm/h)	時	分	降雨基準値 (mm/h)	時	分	降雨基準値 (mm/h)
0	0-10	2.5	6	0-10	4.3	12	0-10	62.4	18	0-10	4.2
	10-20	2.5		10-20	4.4		10-20	41.4		10-20	4.1
	20-30	2.5		20-30	4.6		20-30	33.4		20-30	4.0
	30-40	2.6		30-40	4.7		30-40	23.9		30-40	4.0
	40-50	2.6		40-50	4.8		40-50	20.2		40-50	3.9
	50-60	2.6		50-60	4.9		50-60	17.6		50-60	3.8
1	0-10	2.7	7	0-10	5.0	13	0-10	15.6	19	0-10	3.7
	10-20	2.7		10-20	5.2		10-20	14.1		10-20	3.7
	20-30	2.7		20-30	5.3		20-30	12.9		20-30	3.6
	30-40	2.8		30-40	5.5		30-40	11.8		30-40	3.5
	40-50	2.8		40-50	5.7		40-50	11.0		40-50	3.5
	50-60	2.8		50-60	5.8		50-60	10.3		50-60	3.4
2	0-10	2.9	8	0-10	6.0	14	0-10	9.6	20	0-10	3.4
	10-20	2.9		10-20	6.3		10-20	9.1		10-20	3.3
	20-30	3.0		20-30	6.5		20-30	8.6		20-30	3.3
	30-40	3.0		30-40	6.7		30-40	8.2		30-40	3.2
	40-50	3.0		40-50	7.0		40-50	7.8		40-50	3.2
	50-60	3.1		50-60	7.3		50-60	7.5		50-60	3.1
3	0-10	3.1	9	0-10	7.6	15	0-10	7.2	21	0-10	3.1
	10-20	3.2		10-20	8.0		10-20	6.9		10-20	3.0
	20-30	3.2		20-30	8.4		20-30	6.6		20-30	3.0
	30-40	3.3		30-40	8.9		30-40	6.4		30-40	2.9
	40-50	3.3		40-50	9.4		40-50	6.1		40-50	2.9
	50-60	3.4		50-60	10.0		50-60	5.9		50-60	2.9
4	0-10	3.4	10	0-10	10.6	16	0-10	5.8	22	0-10	2.8
	10-20	3.5		10-20	11.4		10-20	5.6		10-20	2.8
	20-30	3.6		20-30	12.3		20-30	5.4		20-30	2.8
	30-40	3.6		30-40	13.4		30-40	5.3		30-40	2.7
	40-50	3.7		40-50	14.8		40-50	5.1		40-50	2.7
	50-60	3.8		50-60	16.5		50-60	5.0		50-60	2.7
5	0-10	3.8	11	0-10	18.8	17	0-10	4.8	23	0-10	2.6
	10-20	3.9		10-20	21.9		10-20	4.7		10-20	2.6
	20-30	4.0		20-30	25.9		20-30	4.6		20-30	2.6
	30-40	4.1		30-40	36.8		30-40	4.5		30-40	2.5
	40-50	4.2		40-50	48.7		40-50	4.4		40-50	2.5
	50-60	4.3		50-60	122.7		50-60	4.3		50-60	2.5

(建設局土木管理部河川整備課)