

|               |                                    |               |      |          |            |         |         |            |         |         |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|------------|---------|---------|------------|---------|---------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月7日     | 5月12日      | 6月16日   | 7月14日   | 8月4日       | 9月1日    | ---     | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 11:00    | 11:00      | 10:40   | 10:40   | 10:30      | 10:35   | ---     | --- | --- | --- | --- | --- |
| 名称 外畑地域       |                                    |               | 天候   | 晴後一時曇    | 曇後一時雨      | 曇時々晴    | 曇時々晴    | 曇後晴        | 晴       | ---     | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 14.7     | 18.8       | 29.1    | 30.1    | 28.0       | 26.8    | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 12.7       | 17.9    | 20.6    | 26.1       | 27.9    | 27.9    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0       | 0       | 0          | 0       | 0       | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出     | 不検出     | 不検出        | 不検出     | 不検出     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | 0.00005未満  | ---     | ---     | 0.00005未満  | ---     | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | 0.004未満    | ---     | ---     | 0.004未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 0.62       | ---     | ---     | 0.51       | ---     | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.06       | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | 0.0004未満   | ---     | ---     | 0.0004未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.07       | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001      | ---     | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.014      | 0.022   | 0.022   | 0.026      | 0.029   | 0.034   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.008      | 0.010   | 0.009   | 0.006      | 0.011   | 0.010   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001未満    | 0.001未満 | 0.001未満 | 0.002      | 0.002   | 0.002   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.018      | 0.026   | 0.028   | 0.036      | 0.039   | 0.045   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.010      | 0.014   | 0.014   | 0.011      | 0.012   | 0.012   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.004      | 0.004   | 0.006   | 0.008      | 0.008   | 0.009   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | 0.001未満 | 0.001未満 | 0.001未満    | 0.001未満 | 0.001未満 | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | 0.002未満    | ---     | ---     | 0.002未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | 0.002      | ---     | ---     | 0.004      | ---     | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満     | ---     | 0.01未満  | 0.01未満     | ---     | 0.01未満  | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.005未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | 0.002      | ---     | ---     | 0.002      | ---     | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | 4.6        | ---     | ---     | 4.6        | ---     | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | 0.001未満 | 0.001未満    | ---     | 0.001未満 | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 3.8        | 4.3     | 3.7     | 4.0        | 3.1     | 4.2     | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 41         | ---     | 34      | 39         | ---     | 44      | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 58         | ---     | 64      | 71         | ---     | 73      | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | 0.02未満     | ---     | ---     | 0.02未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.005未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | 0.0005未満   | ---     | ---     | 0.0005未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.5        | 0.6     | 0.5     | 0.5        | 0.5     | 0.5     | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8以上8.6以下    |      |          | 7.6        | 7.8     | 7.6     | 7.7        | 7.8     | 7.8     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度以下          | 度    | 0.5      | 0.5未満      | 0.5未満   | 0.5未満   | 0.5未満      | 0.5未満   | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度以下          | 度    | 0.1      | 0.1未満      | 0.1未満   | 0.1未満   | 0.1未満      | 0.1未満   | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5        | 0.4     | 0.5     | 0.5        | 0.6     | 0.4     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |         |            |       |         |            |       |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|---------|------------|-------|---------|------------|-------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月8日     | 5月19日   | 6月2日       | 7月15日 | 8月18日   | 9月16日      | ---   | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:50     | 9:40    | 10:55      | 10:06 | 9:25    | 10:30      | ---   | --- | --- | --- | --- | --- |
| 名称            | 静岡県                                |               | 天候   | 晴後曇      | 曇一時晴    | 曇一時晴       | 曇一時雨  | 晴後一時雨   | 晴          | ---   | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 16.5     | 22.6    | 25.3       | 28.7  | 33.9    | 30.8       | ---   | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 13.6    | 18.8       | 18.4  | 25.0    | 26.0       | 25.8  | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0          | 0     | 0       | 0          | 0     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出        | 不検出   | 不検出     | 不検出        | 不検出   | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | 0.39       | ---   | ---     | 0.51       | ---   | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | 0.08       | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---     | 0.003      | ---   | ---     | 0.006      | ---   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.002   | 0.003      | 0.003 | 0.005   | 0.007      | 0.006 | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---     | 0.007      | ---   | ---     | 0.013      | ---   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.003      | ---   | ---     | 0.005      | ---   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.04    | 0.02       | ---   | 0.03    | 0.04       | ---   | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.007      | ---   | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | 4.7        | ---   | ---     | 4.4        | ---   | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 4.2     | 4.1        | 4.2   | 3.4     | 3.4        | 4.3   | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 21      | 21         | ---   | 22      | 20         | ---   | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 46      | 54         | ---   | 46      | 53         | ---   | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.5     | 7.1        | 7.1   | 7.1     | 7.2        | 7.1   | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.6     | 0.6        | 0.6   | 0.6     | 0.5        | 0.6   | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |            |       |         |            |       |         |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|------------|-------|---------|------------|-------|---------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月7日     | 5月12日      | 6月16日 | 7月14日   | 8月4日       | 9月1日  | ---     | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:15     | 9:25       | 9:10  | 9:10    | 9:05       | 9:10  | ---     | --- | --- | --- | --- | --- |
| 名称            | 水尾地域                               |               | 天候   | 晴後一時曇    | 曇後一時雨      | 曇時々晴  | 曇時々晴    | 曇後晴        | 晴     | ---     | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 10.0     | 16.1       | 23.9  | 27.7    | 28.9       | 27.6  | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 13.9       | 18.7  | 22.5    | 29.5       | 32.1  | 31.1    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0     | 0       | 0          | 0     | ---     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出   | 不検出     | 不検出        | 不検出   | ---     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | 0.004未満    | ---   | ---     | 0.004未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 0.13       | ---   | ---     | 0.13       | ---   | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.06       | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.004      | ---   | ---     | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.004      | ---   | ---     | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.002      | ---   | ---     | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.004未満    | ---   | ---     | 0.009      | ---   | ---     | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001      | ---   | ---     | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.003      | ---   | ---     | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | 0.002未満    | ---   | ---     | 0.002未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | 0.002未満    | ---   | ---     | 0.003      | ---   | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満     | ---   | 0.01    | 0.01       | 0.02  | ---     | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | 0.005未満    | ---   | ---     | 0.005未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | 0.001      | ---   | ---     | 0.002      | ---   | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | 6.8        | ---   | ---     | 6.5        | ---   | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | 0.001未満 | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 4.6        | 4.5   | 4.6     | 4.8        | 3.8   | 4.9     | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 91         | ---   | 78      | 78         | ---   | 86      | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 125        | ---   | 121     | 126        | ---   | 126     | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | 0.005未満    | ---   | ---     | 0.005未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.3        | 7.1   | 7.1     | 7.2        | 7.2   | 7.2     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5        | 0.4   | 0.6     | 0.4        | 0.6   | 0.4     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月7日     | 5月12日      | 6月16日 | 7月14日   | 8月4日       | 9月1日  | ---     | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|------------|-------|---------|------------|-------|---------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:55     | 10:00      | 9:50  | 9:40    | 9:30       | 9:35  | ---     | --- | --- | --- | --- | --- |
| 名称            | 岩陰地域                               |               | 天候   | 晴後一時曇    | 曇後一時雨      | 曇時々晴  | 曇時々晴    | 曇後晴        | 晴     | ---     | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 10.7     | 18.1       | 27.2  | 27.5    | 29.3       | 26.5  | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 11.8       | 16.8  | 21.1    | 27.0       | 28.7  | 27.7    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0     | 0       | 0          | 0     | ---     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出   | 不検出     | 不検出        | 不検出   | ---     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | 0.004未満    | ---   | ---     | 0.004未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 0.33       | ---   | ---     | 0.32       | ---   | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001      | ---   | ---     | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001      | ---   | ---     | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.004未満    | ---   | ---     | 0.004未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001      | ---   | ---     | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | 0.002未満    | ---   | ---     | 0.002未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | 0.002未満    | ---   | ---     | 0.004      | ---   | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.03       | 0.02  | 0.03    | 0.02       | 0.02  | ---     | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | 0.005未満    | ---   | ---     | 0.005未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001      | ---   | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | 4.0        | ---   | ---     | 4.1        | ---   | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | 0.001未満 | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 4.2        | 4.2   | 4.1     | 4.1        | 3.2   | 4.3     | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 25         | ---   | 24      | 25         | ---   | 26      | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 36         | ---   | 55      | 54         | ---   | 53      | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | 0.005未満    | ---   | ---     | 0.005未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.3        | 7.0   | 7.0     | 7.0        | 7.1   | 7.1     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5        | 0.4   | 0.6     | 0.7        | 0.7   | 0.5     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月7日     | 5月12日      | 6月16日 | 7月14日   | 8月4日       | 9月1日  | ---     | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|------------|-------|---------|------------|-------|---------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 11:10    | 9:15       | 10:41 | 9:05    | 10:45      | 9:10  | ---     | --- | --- | --- | --- | --- |
| 名称            | 中川地域                               |               | 天候   | 晴後一時曇    | 曇後一時雨      | 曇時々晴  | 曇時々晴    | 曇後晴        | 晴     | ---     | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 18.1     | 16.6       | 26.8  | 25.8    | 32.9       | 28.8  | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 12.6       | 17.3  | 20.7    | 26.5       | 28.8  | 27.8    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0     | 0       | 0          | 0     | ---     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出   | 不検出     | 不検出        | 不検出   | ---     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | 0.004未満    | ---   | ---     | 0.004未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 0.12       | ---   | ---     | 0.14       | ---   | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.002      | ---   | ---     | 0.007      | ---   | ---     | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.002      | 0.003 | 0.005   | 0.005      | 0.005 | ---     | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001      | ---   | ---     | 0.002      | ---   | ---     | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.005      | ---   | ---     | 0.013      | ---   | ---     | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.001      | ---   | ---     | 0.003      | ---   | ---     | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.002      | ---   | ---     | 0.004      | ---   | ---     | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | 0.002未満    | ---   | ---     | 0.002未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | 0.004      | ---   | ---     | 0.005      | ---   | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満     | ---   | 0.01    | 0.02       | 0.02  | ---     | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | 0.005未満    | ---   | ---     | 0.008      | ---   | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | 0.002      | ---   | ---     | 0.003      | ---   | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | 8.6        | ---   | ---     | 9.1        | ---   | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | 0.001未満 | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 5.3        | 5.3   | 5.2     | 5.6        | 4.7   | 5.7     | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 61         | ---   | 66      | 61         | ---   | 76      | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 84         | ---   | 101     | 99         | ---   | 109     | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | 0.005未満    | ---   | ---     | 0.005未満    | ---   | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.1        | 7.0   | 7.1     | 7.1        | 7.2   | 7.1     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5        | 0.6   | 0.4     | 0.4        | 0.5   | 0.5     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月7日     | 5月12日      | 6月16日   | 7月14日   | 8月4日       | 9月1日    | ---     | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|------------|---------|---------|------------|---------|---------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 10:45    | 9:45       | 10:20   | 9:25    | 10:20      | 9:25    | ---     | --- | --- | --- | --- | --- |
| 名称            | 小野郷地域                              |               | 天候   | 晴後一時曇    | 曇後一時雨      | 曇時々晴    | 曇時々晴    | 曇後晴        | 晴       | ---     | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 17.5     | 16.0       | 28.6    | 25.2    | 29.4       | 28.5    | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 12.3       | 17.8    | 21.6    | 28.4       | 30.6    | 28.5    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0       | 0       | 0          | 0       | ---     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出     | 不検出     | 不検出        | 不検出     | ---     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | 0.00005未満  | ---     | ---     | 0.00005未満  | ---     | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | 0.001      | ---     | ---     | 0.001      | ---     | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | 0.004未満    | ---     | ---     | 0.004未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 0.06       | ---     | ---     | 0.06       | ---     | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.09       | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | 0.0004未満   | ---     | ---     | 0.0004未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.001      | 0.002   | 0.003   | 0.006      | 0.008   | 0.008   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | 0.002   | 0.003   | 0.004      | 0.006   | 0.005   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001未満    | 0.001   | 0.001   | 0.002      | 0.003   | 0.003   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.004未満    | 0.005   | 0.006   | 0.012      | 0.015   | 0.015   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001      | ---     | ---     | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満    | 0.002   | 0.002   | 0.004      | 0.004   | 0.004   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | 0.001未満 | 0.001未満 | 0.001未満    | 0.001未満 | 0.001未満 | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | 0.002未満    | ---     | ---     | 0.002未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | 0.002      | ---     | ---     | 0.004      | ---     | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満     | ---     | 0.01未満  | 0.01未満     | ---     | 0.01未満  | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.009      | ---     | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | 0.001      | ---     | ---     | 0.003      | ---     | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | 8.6        | ---     | ---     | 8.1        | ---     | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | 0.001未満 | 0.001      | ---     | 0.001未満 | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 4.2        | 4.2     | 4.1     | 4.2        | 3.3     | 4.3     | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 69         | ---     | 73      | 76         | ---     | 72      | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 108        | ---     | 126     | 119        | ---     | 113     | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | 0.02未満     | ---     | ---     | 0.02未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.005未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | 0.0005未満   | ---     | ---     | 0.0005未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満      | 0.3未満   | 0.3未満   | 0.3未満      | 0.3未満   | 0.3未満   | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.4        | 7.5     | 7.5     | 7.5        | 7.5     | 7.5     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満      | 0.5未満   | 0.5未満   | 0.5未満      | 0.5未満   | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満      | 0.1未満   | 0.1未満   | 0.1未満      | 0.1未満   | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.4        | 0.5     | 0.4     | 0.3        | 0.4     | 0.4     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月8日     | 5月19日   | 6月2日       | 7月15日 | 8月18日   | 9月16日      | ---   | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|---------|------------|-------|---------|------------|-------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 8:55     | 9:00    | 9:05       | 10:35 | 8:50    | 9:00       | ---   | --- | --- | --- | --- | --- |
| 名称 雲ヶ畑地域      |                                    |               | 天候   | 晴後曇      | 曇一時晴    | 曇一時晴       | 曇一時雨  | 晴後一時雨   | 晴          | ---   | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 10.2     | 17.0    | 16.0       | 25.2  | 24.2    | 24.0       | ---   | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 11.5    | 17.2       | 17.0  | 24.6    | 24.6       | 24.3  | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0          | 0     | 0       | 0          | ---   | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出        | 不検出   | 不検出     | 不検出        | ---   | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 10            | シアン化合物イオン及び塩化シアン                   | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | 0.45       | ---   | ---     | 0.43       | ---   | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.16    | 0.14       | 0.14  | 0.14    | 0.06       | 0.13  | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---     | 0.003      | ---   | ---     | 0.008      | ---   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.002      | ---   | ---     | 0.004      | ---   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---     | 0.006      | ---   | ---     | 0.014      | ---   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.002      | ---   | ---     | 0.004      | ---   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | 0.002      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.05    | 0.04       | 0.04  | 0.04    | 0.03       | 0.05  | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | 12.8       | ---   | ---     | 11.8       | ---   | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 4.6     | 4.5        | 4.6   | 3.7     | 3.7        | 4.8   | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 53      | 52         | ---   | 53      | 55         | ---   | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 93      | 99         | ---   | 93      | 110        | ---   | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.4     | 7.5        | 7.5   | 7.4     | 7.3        | 7.5   | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.3     | 0.5        | 0.5   | 0.4     | 0.4        | 0.4   | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |         |            |       |         |            |       |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|---------|------------|-------|---------|------------|-------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月8日     | 5月19日   | 6月2日       | 7月15日 | 8月18日   | 9月16日      | ---   | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:32     | 10:05   | 10:35      | 9:50  | 9:45    | 9:25       | ---   | --- | --- | --- | --- | --- |
| 名称 鞍馬・貴船地域    |                                    |               | 天候   | 晴後曇      | 曇一時晴    | 曇一時晴       | 曇一時雨  | 晴後一時雨   | 晴          | ---   | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 14.7     | 22.1    | 23.5       | 26.1  | 28.3    | 25.7       | ---   | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 13.8    | 19.3       | 19.0  | 26.0    | 25.6       | 25.6  | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0          | 0     | 0       | 0          | 0     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出        | 不検出   | 不検出     | 不検出        | 不検出   | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | 0.17       | ---   | ---     | 0.22       | ---   | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | 0.08       | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | 0.003      | ---   | ---     | 0.004      | ---   | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満  | 0.01未満     | ---   | 0.01未満  | 0.01未満     | ---   | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | 6.6        | ---   | ---     | 6.1        | ---   | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 5.1     | 4.8        | 4.9   | 4.0     | 3.9        | 4.8   | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 48      | 48         | ---   | 53      | 49         | ---   | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 76      | 83         | ---   | 74      | 84         | ---   | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000002   | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.2     | 7.1        | 7.2   | 7.1     | 7.1        | 7.0   | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.6     | 0.7        | 0.7   | 0.7     | 0.6        | 0.6   | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |         |            |       |         |            |       |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|---------|------------|-------|---------|------------|-------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月8日     | 5月19日   | 6月2日       | 7月15日 | 8月18日   | 9月16日      | ---   | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 10:00    | 10:35   | 10:30      | 10:39 | 10:20   | 10:25      | ---   | --- | --- | --- | --- | --- |
| 名称            | 久多地域                               |               | 天候   | 晴後曇      | 曇一時晴    | 曇一時晴       | 曇一時雨  | 晴後一時雨   | 晴          | ---   | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 14.3     | 21.8    | 18.0       | 28.7  | 30.9    | 26.4       | ---   | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 11.1    | 18.5       | 17.3  | 26.6    | 26.6       | 25.8  | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0          | 0     | 0       | 0          | ---   | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出        | 不検出   | 不検出     | 不検出        | ---   | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | 0.14       | ---   | ---     | 0.21       | ---   | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | 0.07       | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.006      | ---   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | 0.003      | ---   | ---     | 0.003      | ---   | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01    | 0.01未満     | ---   | 0.01    | 0.01未満     | ---   | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | 0.001      | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | 7.0        | ---   | ---     | 6.9        | ---   | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 4.9     | 4.8        | 4.7   | 3.9     | 3.9        | 4.8   | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 24      | 25         | ---   | 28      | 26         | ---   | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 51      | 55         | ---   | 50      | 60         | ---   | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000002   | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.2     | 7.0        | 7.0   | 7.0     | 7.0        | 7.0   | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.4     | 0.6        | 0.5   | 0.5     | 0.4        | 0.6   | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |       |         |            |       |         |            |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|-------|---------|------------|-------|---------|------------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月1日     | 5月20日 | 6月17日   | 7月1日       | 8月19日 | 9月2日    | ---        | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:35     | 11:45 | 9:10    | 10:40      | 11:20 | 10:50   | ---        | --- | --- | --- | --- | --- |
| 名称 広河原・花脊地域   |                                    |               | 天候   | 曇        | 晴     | 晴       | 曇時々晴       | 晴     | 晴       | ---        | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 7.9      | 25.2  | 26.7    | 31.7       | 31.6  | 29.2    | ---        | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 9.4   | 18.7    | 20.0       | 23.9  | 26.7    | 27.5       | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0     | 0       | 0          | 0     | 0       | ---        | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出   | 不検出     | 不検出        | 不検出   | 不検出     | ---        | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---   | ---     | 0.00005未満  | ---   | ---     | 0.00005未満  | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---   | ---     | 0.004未満    | ---   | ---     | 0.004未満    | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---   | ---     | 0.30       | ---   | ---     | 0.34       | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---   | ---     | 0.05未満     | ---   | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---   | ---     | 0.05未満     | ---   | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | ---   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---   | ---     | 0.0004未満   | ---   | ---     | 0.0004未満   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---   | ---     | 0.05未満     | ---   | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001      | ---   | ---     | 0.003      | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.002      | ---   | ---     | 0.003      | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---   | ---     | 0.002      | ---   | ---     | 0.003      | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---   | ---     | 0.005      | ---   | ---     | 0.009      | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.002      | ---   | ---     | 0.003      | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---   | ---     | 0.001未満    | ---   | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---   | ---     | 0.002未満    | ---   | ---     | 0.002未満    | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---   | ---     | 0.004      | ---   | ---     | 0.004      | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | ---   | 0.01    | 0.01       | ---   | 0.01未満  | 0.01       | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---   | ---     | 0.005未満    | ---   | ---     | 0.006      | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---   | ---     | 0.002      | ---   | ---     | 0.002      | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---   | ---     | 5.7        | ---   | ---     | 6.0        | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | ---   | 0.001未満 | 0.001未満    | ---   | 0.001未満 | 0.001未満    | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 6.4   | 6.0     | 5.5        | 5.2   | 4.3     | 5.3        | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | ---   | 16      | 16         | ---   | 21      | 18         | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | ---   | 39      | 53         | ---   | 43      | 48         | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---   | ---     | 0.02未満     | ---   | ---     | 0.02未満     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---   | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---   | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---   | ---     | 0.005未満    | ---   | ---     | 0.005未満    | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---   | ---     | 0.0005未満   | ---   | ---     | 0.0005未満   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.2   | 7.2     | 7.1        | 7.1   | 7.0     | 7.0        | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし  | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5   | 0.5     | 0.5        | 0.5   | 0.6     | 0.6        | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月8日     | 5月19日   | 6月2日       | 7月15日 | 8月18日   | 9月16日      | ---   | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|---------|------------|-------|---------|------------|-------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 10:53    | 10:50   | 9:55       | 9:20  | 10:15   | 10:00      | ---   | --- | --- | --- | --- | --- |
| 名称            | 別所地域                               |               | 天候   | 晴後曇      | 曇一時晴    | 曇一時晴       | 曇一時雨  | 晴後一時雨   | 晴          | ---   | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 18.2     | 23.2    | 19.5       | 26.8  | 28.6    | 30.1       | ---   | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 12.4    | 19.5       | 18.1  | 27.7    | 27.4       | 25.8  | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0          | 0     | 0       | 0          | ---   | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出        | 不検出   | 不検出     | 不検出        | ---   | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | 0.53       | ---   | ---     | 0.52       | ---   | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004      | ---   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01    | 0.02       | 0.02  | 0.02    | 0.02       | 0.04  | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | 18.5       | ---   | ---     | 16.8       | ---   | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 13.7    | 14.1       | 14.3  | 15.1    | 14.9       | 14.9  | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 51      | 56         | ---   | 60      | 54         | ---   | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 109     | 118        | ---   | 115     | 135        | ---   | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.4     | 7.1        | 7.1   | 7.1     | 7.0        | 7.0   | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5     | 0.6        | 0.7   | 0.7     | 0.7        | 0.6   | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月8日     | 5月19日   | 6月2日       | 7月15日 | 8月18日   | 9月16日      | ---   | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|---------|------------|-------|---------|------------|-------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:10     | 9:35    | 9:30       | 9:42  | 9:20    | 9:35       | ---   | --- | --- | --- | --- | --- |
| 名称            | 百井地域                               |               | 天候   | 晴後曇      | 曇一時晴    | 曇一時晴       | 曇一時雨  | 晴後一時雨   | 晴          | ---   | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 10.3     | 19.5    | 18.7       | 24.9  | 28.2    | 27.9       | ---   | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 8.2     | 14.5       | 14.0  | 21.8    | 20.7       | 20.7  | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0          | 0     | 0       | 0          | ---   | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出        | 不検出   | 不検出     | 不検出        | ---   | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | 0.14       | ---   | ---     | 0.16       | ---   | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | 0.07       | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---   | ---     | 0.05未満     | ---   | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---     | 0.004未満    | ---   | ---     | 0.004未満    | ---   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001      | ---   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---   | ---     | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | 0.002未満    | ---   | ---     | 0.002未満    | ---   | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | 0.016      | ---   | ---     | 0.017      | ---   | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満  | 0.01未満     | ---   | 0.01    | 0.01未満     | ---   | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | 0.002      | ---   | ---     | 0.002      | ---   | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | 12.3       | ---   | ---     | 12.8       | ---   | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 6.4     | 5.8        | 5.7   | 3.9     | 4.3        | 4.8   | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 22      | 21         | ---   | 19      | 21         | ---   | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 68      | 70         | ---   | 61      | 89         | ---   | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | 0.02未満     | ---   | ---     | 0.02未満     | ---   | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | 0.005未満    | ---   | ---     | 0.005未満    | ---   | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.3未満      | 0.3未満 | 0.3未満   | 0.3未満      | 0.3未満 | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.2     | 7.0        | 7.0   | 7.1     | 7.0        | 7.0   | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.4     | 0.7        | 0.6   | 0.6     | 0.5        | 0.7   | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |         |            |         |         |            |         |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|---------|------------|---------|---------|------------|---------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月8日     | 5月19日   | 6月2日       | 7月15日   | 8月18日   | 9月16日      | ---     | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 8:50     | 8:55    | 9:00       | 9:06    | 8:50    | 9:05       | ---     | --- | --- | --- | --- | --- |
| 名称 大原第1地域     |                                    |               | 天候   | 晴後曇      | 曇一時晴    | 曇一時晴       | 曇一時雨    | 晴後一時雨   | 晴          | ---     | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 14.3     | 21.9    | 22.5       | 29.0    | 29.6    | 30.0       | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 12.1    | 18.4       | 19.0    | 27.0    | 26.8       | 27.0    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0          | 0       | 0       | 0          | ---     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出        | 不検出     | 不検出     | 不検出        | ---     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | 0.00005未満  | ---     | ---     | 0.00005未満  | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | 0.004未満    | ---     | ---     | 0.004未満    | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | 0.35       | ---     | ---     | 0.44       | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | 0.07       | ---     | ---     | 0.05未満     | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | 0.0004未満   | ---     | ---     | 0.0004未満   | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.07    | 0.09       | 0.09    | 0.10    | 0.06       | 0.12    | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.002   | 0.006      | 0.001未満 | 0.005   | 0.007      | 0.005   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.004      | ---     | ---     | 0.004      | ---     | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001未満 | 0.001未満    | 0.001   | 0.002   | 0.001      | 0.002   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | 0.001未満    | ---     | ---     | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.004   | 0.009      | 0.004未満 | 0.011   | 0.012      | 0.011   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---     | 0.004      | ---     | ---     | 0.004      | ---     | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.002   | 0.003      | 0.001   | 0.004   | 0.004      | 0.004   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | 0.001未満 | 0.001未満 | 0.001未満    | 0.001未満 | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | 0.002未満    | ---     | ---     | 0.002未満    | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | 0.002未満    | ---     | ---     | 0.002      | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満  | 0.01未満     | ---     | 0.01未満  | 0.01未満     | ---     | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | 0.005未満    | ---     | ---     | 0.005未満    | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | 0.003      | ---     | ---     | 0.004      | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | 3.5        | ---     | ---     | 3.1        | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満    | ---     | 0.001未満 | 0.001未満    | ---     | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 5.5     | 4.2        | 4.1     | 2.9     | 2.4        | 3.8     | --- | --- | --- | --- | --- |
| 39            | カルシウム, マグネシウム等 (硬度)                | 300mg/L以下     | mg/L | 1        | 20      | 18         | ---     | 18      | 17         | ---     | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 41      | 44         | ---     | 34      | 49         | ---     | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | 0.02未満     | ---     | ---     | 0.02未満     | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | 0.005未満    | ---     | ---     | 0.005未満    | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | 0.0005未満   | ---     | ---     | 0.0005未満   | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物 (全有機炭素 (TOC) の量)               | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.4        | 0.3未満   | 0.3未満   | 0.3        | 0.3未満   | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 6.6     | 6.9        | 6.9     | 6.9     | 6.8        | 6.9     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満      | 0.5未満   | 0.5未満   | 0.5未満      | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満      | 0.1未満   | 0.1未満   | 0.1未満      | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5     | 0.6        | 0.7     | 0.6     | 0.6        | 0.8     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書<br>(令和7年4月～9月分) |                                    |               | 日時   | 4月8日     | 5月19日    | 6月2日       | 7月15日 | 8月18日   | 9月16日      | ---   | ---  | --- | --- | --- | --- |
|-------------------------------|------------------------------------|---------------|------|----------|----------|------------|-------|---------|------------|-------|------|-----|-----|-----|-----|
| 名称 大原第2地域                     |                                    |               | 時刻   | 8:30     | 11:50    | 8:40       | 8:45  | 8:35    | 8:50       | ---   | ---  | --- | --- | --- | --- |
| 場所 給水栓                        |                                    |               | 天候   | 晴後曇      | 曇一時晴     | 曇一時晴       | 曇一時雨  | 晴後一時雨   | 晴          | ---   | ---  | --- | --- | --- | --- |
| 番号 項目名                        |                                    |               | 気温   | 13.9     | 23.3     | 24.3       | 27.3  | 28.2    | 27.9       | ---   | ---  | --- | --- | --- | --- |
|                               |                                    |               | 基準値  | 単位       | 定量下限値/水温 | 12.9       | 19.3  | 20.3    | 28.1       | 26.6  | 26.8 | --- | --- | --- | --- |
| 1                             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0        | 0          | 0     | 0       | 0          | ---   | ---  | --- | --- | --- | --- |
| 2                             | 大腸菌                                | 検出されないこと      |      |          | 不検出      | 不検出        | 不検出   | 不検出     | 不検出        | ---   | ---  | --- | --- | --- | --- |
| 3                             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---      | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---  | --- | --- | --- | --- |
| 4                             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---      | 0.00005未満  | ---   | ---     | 0.00005未満  | ---   | ---  | --- | --- | --- | --- |
| 5                             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 6                             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 7                             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---      | 0.002      | ---   | ---     | 0.002      | ---   | ---  | --- | --- | --- | --- |
| 8                             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 9                             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---      | 0.004未満    | ---   | ---     | 0.004未満    | ---   | ---  | --- | --- | --- | --- |
| 10                            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 11                            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 1.2      | 1.5        | 1.7   | 1.6     | 2.3        | 1.2   | ---  | --- | --- | --- | --- |
| 12                            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---      | 0.09       | ---   | ---     | 0.07       | ---   | ---  | --- | --- | --- | --- |
| 13                            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---      | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---  | --- | --- | --- | --- |
| 14                            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---      | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---  | --- | --- | --- | --- |
| 15                            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 16                            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---      | 0.0004未満   | ---   | ---     | 0.0004未満   | ---   | ---  | --- | --- | --- | --- |
| 17                            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---      | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---  | --- | --- | --- | --- |
| 18                            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---      | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---  | --- | --- | --- | --- |
| 19                            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---      | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---  | --- | --- | --- | --- |
| 20                            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---      | 0.0002未満   | ---   | ---     | 0.0002未満   | ---   | ---  | --- | --- | --- | --- |
| 21                            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---      | 0.05未満     | ---   | ---     | 0.05未満     | ---   | ---  | --- | --- | --- | --- |
| 22                            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 23                            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 24                            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 25                            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001      | ---   | ---  | --- | --- | --- | --- |
| 26                            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 27                            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---      | 0.004未満    | ---   | ---     | 0.004未満    | ---   | ---  | --- | --- | --- | --- |
| 28                            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 29                            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001      | ---   | ---  | --- | --- | --- | --- |
| 30                            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---      | 0.001未満    | ---   | ---     | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 31                            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---      | 0.002未満    | ---   | ---     | 0.002未満    | ---   | ---  | --- | --- | --- | --- |
| 32                            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---      | 0.002      | ---   | ---     | 0.003      | ---   | ---  | --- | --- | --- | --- |
| 33                            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満   | 0.01未満     | ---   | 0.01未満  | 0.01未満     | ---   | ---  | --- | --- | --- | --- |
| 34                            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---      | 0.005未満    | ---   | ---     | 0.005未満    | ---   | ---  | --- | --- | --- | --- |
| 35                            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---      | 0.003      | ---   | ---     | 0.003      | ---   | ---  | --- | --- | --- | --- |
| 36                            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---      | 4.6        | ---   | ---     | 5.0        | ---   | ---  | --- | --- | --- | --- |
| 37                            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満  | 0.001未満    | ---   | 0.001未満 | 0.001未満    | ---   | ---  | --- | --- | --- | --- |
| 38                            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 6.2      | 5.5        | 5.5   | 4.1     | 4.1        | 4.5   | ---  | --- | --- | --- | --- |
| 39                            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 33       | 35         | ---   | 45      | 47         | ---   | ---  | --- | --- | --- | --- |
| 40                            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 64       | 73         | ---   | 79      | 115        | ---   | ---  | --- | --- | --- | --- |
| 41                            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---      | 0.02未満     | ---   | ---     | 0.02未満     | ---   | ---  | --- | --- | --- | --- |
| 42                            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---      | 0.000001未満 | ---   | ---     | 0.000001   | ---   | ---  | --- | --- | --- | --- |
| 43                            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---      | 0.000001未満 | ---   | ---     | 0.000001未満 | ---   | ---  | --- | --- | --- | --- |
| 44                            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---      | 0.005未満    | ---   | ---     | 0.005未満    | ---   | ---  | --- | --- | --- | --- |
| 45                            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---      | 0.0005未満   | ---   | ---     | 0.0005未満   | ---   | ---  | --- | --- | --- | --- |
| 46                            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満    | 0.3未満      | 0.3未満 | 0.3未満   | 0.3        | 0.3未満 | ---  | --- | --- | --- | --- |
| 47                            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.7      | 6.6        | 6.6   | 6.6     | 6.5        | 6.5   | ---  | --- | --- | --- | --- |
| 48                            | 味                                  | 異常でないこと       |      |          | 異常なし     | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | ---  | --- | --- | --- | --- |
| 49                            | 臭気                                 | 異常でないこと       |      |          | 異常なし     | 異常なし       | 異常なし  | 異常なし    | 異常なし       | 異常なし  | ---  | --- | --- | --- | --- |
| 50                            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満    | 0.5未満      | 0.5未満 | 0.5未満   | 0.5未満      | 0.5未満 | ---  | --- | --- | --- | --- |
| 51                            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満    | 0.1未満      | 0.1未満 | 0.1未満   | 0.1未満      | 0.1未満 | ---  | --- | --- | --- | --- |
| 52                            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.5      | 0.5        | 0.5   | 0.6     | 0.6        | 0.7   | ---  | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |         |         |            |         |         |            |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|---------|---------|------------|---------|---------|------------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月1日     | 5月20日   | 6月17日   | 7月1日       | 8月19日   | 9月2日    | ---        | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 10:15    | 10:45   | 10:15   | 10:20      | 9:45    | 10:00   | ---        | --- | --- | --- | --- | --- |
| 名称 京北 黒田地域    |                                    |               | 天候   | 曇        | 晴       | 晴       | 曇時々晴       | 晴       | 晴       | ---        | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 7.8      | 26.6    | 29.5    | 32.7       | 31.2    | 28.8    | ---        | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 11.4    | 21.6    | 23.5       | 28.4    | 30.8    | 30.6       | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0       | 0          | 0       | 0       | 0          | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出     | 不検出        | 不検出     | 不検出     | 不検出        | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | ---     | 0.00005未満  | ---     | ---     | 0.00005未満  | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | ---     | 0.004未満    | ---     | ---     | 0.004未満    | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | ---     | 0.43       | ---     | ---     | 0.39       | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | ---     | 0.05未満     | ---     | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | ---     | 0.05未満     | ---     | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | ---     | 0.0004未満   | ---     | ---     | 0.0004未満   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.10    | 0.10    | 0.12       | 0.11    | 0.05    | 0.06       | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.013   | 0.015   | 0.023      | 0.018   | 0.012   | 0.021      | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.009   | 0.008   | 0.007      | 0.005   | 0.007   | 0.009      | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001   | 0.002   | 0.001      | 0.002   | 0.003   | 0.004      | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.019   | 0.023   | 0.031      | 0.028   | 0.023   | 0.035      | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.001   | 0.012   | 0.021      | 0.013   | 0.007   | 0.010      | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.005   | 0.006   | 0.007      | 0.008   | 0.008   | 0.010      | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満 | 0.001未満    | 0.001未満 | 0.001未満 | 0.001未満    | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | ---     | 0.002未満    | ---     | ---     | 0.002未満    | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | ---     | 0.002未満    | ---     | ---     | 0.002      | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満  | 0.01未満  | 0.01未満     | 0.01    | 0.04    | 0.02       | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | ---     | 0.005未満    | ---     | ---     | 0.005未満    | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | ---     | 0.002      | ---     | ---     | 0.003      | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | ---     | 3.7        | ---     | ---     | 4.2        | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満 | 0.001未満    | ---     | 0.001未満 | 0.001未満    | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 3.8     | 3.8     | 3.8        | 4.0     | 3.2     | 4.2        | --- | --- | --- | --- | --- |
| 39            | カルシウム, マグネシウム等(硬度)                 | 300mg/L以下     | mg/L | 1        | ---     | 20      | 16         | ---     | 19      | 23         | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | ---     | 41      | 48         | ---     | 38      | 49         | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | ---     | 0.02未満     | ---     | ---     | 0.02未満     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | ---     | 0.000002   | ---     | ---     | 0.000001未満 | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | ---     | 0.000001未満 | ---     | ---     | 0.000001未満 | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | ---     | 0.005未満    | ---     | ---     | 0.005未満    | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | ---     | 0.0005未満   | ---     | ---     | 0.0005未満   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.5     | 0.4     | 0.5        | 0.3未満   | 0.3     | 0.4        | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.4     | 7.5     | 7.4        | 7.4     | 7.4     | 7.5        | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | 異常なし       | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | 異常なし       | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満   | 0.5未満      | 0.5未満   | 0.5未満   | 0.5未満      | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満   | 0.1未満      | 0.1未満   | 0.1未満   | 0.1未満      | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.4     | 0.6     | 0.4        | 0.4     | 0.7     | 0.6        | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |            |            |            |            |            |            |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|------------|------------|------------|------------|------------|------------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月1日     | 5月20日      | 6月17日      | 7月1日       | 8月19日      | 9月2日       | ---        | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:30     | 10:00      | 11:00      | 9:35       | 10:35      | 9:20       | ---        | --- | --- | --- | --- | --- |
| 名称 京北 弓削地域    |                                    |               | 天候   | 曇        | 晴          | 晴          | 曇時々晴       | 晴          | 晴          | ---        | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 8.1      | 23.3       | 31.3       | 30.1       | 31.3       | 29.5       | ---        | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 10.3       | 19.0       | 21.9       | 25.9       | 28.0       | 28.8       | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0          | 0          | 0          | 0          | ---        | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出        | 不検出        | 不検出        | 不検出        | ---        | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---        | ---        | 0.0002未満   | ---        | ---        | 0.0002未満   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---        | ---        | 0.00005未満  | ---        | ---        | 0.00005未満  | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---        | ---        | 0.004未満    | ---        | ---        | 0.004未満    | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---        | ---        | 0.22       | ---        | ---        | 0.26       | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---        | ---        | 0.05未満     | ---        | ---        | 0.05       | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---        | ---        | 0.05未満     | ---        | ---        | 0.05未満     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | ---        | ---        | 0.0002未満   | ---        | ---        | 0.0002未満   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---        | ---        | 0.0004未満   | ---        | ---        | 0.0004未満   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---        | ---        | 0.0002未満   | ---        | ---        | 0.0002未満   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---        | ---        | 0.0002未満   | ---        | ---        | 0.0002未満   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---        | ---        | 0.0002未満   | ---        | ---        | 0.0002未満   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---        | ---        | 0.0002未満   | ---        | ---        | 0.0002未満   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---        | ---        | 0.08       | ---        | ---        | 0.05未満     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.001      | 0.002      | 0.006      | 0.004      | 0.004      | 0.004      | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.005      | ---        | ---        | 0.002      | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001      | 0.001      | 0.001      | 0.002      | 0.002      | 0.002      | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.001未満    | ---        | ---        | 0.001未満    | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.004      | 0.005      | 0.010      | 0.009      | 0.010      | 0.009      | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | ---        | ---        | 0.004      | ---        | ---        | 0.001      | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.002      | 0.002      | 0.003      | 0.003      | 0.004      | 0.003      | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | 0.001未満    | 0.001未満    | 0.001未満    | 0.001未満    | 0.001未満    | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---        | ---        | 0.002未満    | ---        | ---        | 0.002未満    | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---        | ---        | 0.003      | ---        | ---        | 0.004      | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01       | 0.02       | 0.02       | 0.03       | 0.03       | 0.04       | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---        | ---        | 0.005未満    | ---        | ---        | 0.005未満    | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---        | ---        | 0.001      | ---        | ---        | 0.005      | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---        | ---        | 5.2        | ---        | ---        | 6.0        | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | ---        | 0.001未満    | 0.001未満    | ---        | 0.001未満    | 0.001未満    | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 7.1        | 6.7        | 6.9        | 6.7        | 6.0        | 6.9        | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | ---        | 20         | 21         | ---        | 22         | 26         | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | ---        | 43         | 55         | ---        | 43         | 57         | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---        | ---        | 0.02未満     | ---        | ---        | 0.02未満     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | 0.000001未満 | 0.000001未満 | 0.000001未満 | 0.000001未満 | 0.000001未満 | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | 0.000001未満 | 0.000001未満 | 0.000001未満 | 0.000001未満 | 0.000001未満 | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---        | ---        | 0.005未満    | ---        | ---        | 0.005未満    | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---        | ---        | 0.0005未満   | ---        | ---        | 0.0005未満   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満      | 0.3未満      | 0.3未満      | 0.3未満      | 0.3未満      | 0.4        | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.2        | 7.3        | 7.2        | 7.2        | 7.3        | 7.4        | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし       | 異常なし       | 異常なし       | 異常なし       | 異常なし       | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし       | 異常なし       | 異常なし       | 異常なし       | 異常なし       | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満      | 0.5未満      | 0.5未満      | 0.5未満      | 0.5未満      | 0.5未満      | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満      | 0.1未満      | 0.1未満      | 0.1未満      | 0.1未満      | 0.1未満      | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.6        | 0.6        | 0.5        | 0.5        | 0.7        | 0.6        | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月1日     | 5月20日   | 6月17日   | 7月1日       | 8月19日   | 9月2日    | ---        | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|---------|---------|------------|---------|---------|------------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:55     | 10:25   | 10:30   | 10:00      | 10:10   | 9:45    | ---        | --- | --- | --- | --- | --- |
| 名称 京北 小塩地域    |                                    |               | 天候   | 曇        | 晴       | 晴       | 曇時々晴       | 晴       | 晴       | ---        | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 8.0      | 26.6    | 30.2    | 30.9       | 31.5    | 30.4    | ---        | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 11.5    | 18.5    | 22.1       | 24.1    | 27.0    | 27.7       | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0       | 0       | 0          | 0       | 0       | 0          | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出     | 不検出     | 不検出        | 不検出     | 不検出     | 不検出        | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | ---     | ---     | 0.00005未満  | ---     | ---     | 0.00005未満  | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | ---     | ---     | 0.004未満    | ---     | ---     | 0.004未満    | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | ---     | ---     | 0.29       | ---     | ---     | 0.28       | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | ---     | ---     | 0.05未満     | ---     | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | ---     | ---     | 0.05未満     | ---     | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.002mg/L以下   | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | ---     | ---     | 0.0004未満   | ---     | ---     | 0.0004未満   | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | ---     | ---     | 0.0002未満   | ---     | ---     | 0.0002未満   | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | ---     | ---     | 0.05未満     | ---     | ---     | 0.05未満     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.003      | ---     | ---     | 0.003      | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.003      | ---     | ---     | 0.002      | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | ---     | ---     | 0.001      | ---     | ---     | 0.002      | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | ---     | ---     | 0.006      | ---     | ---     | 0.008      | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.001未満 | 0.001未満 | 0.001      | 0.001未満 | 0.001   | 0.001未満    | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.002      | ---     | ---     | 0.003      | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | ---     | ---     | 0.001未満    | ---     | ---     | 0.001未満    | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | ---     | ---     | 0.002未満    | ---     | ---     | 0.002未満    | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | ---     | ---     | 0.015      | ---     | ---     | 0.017      | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | ---     | 0.01未満  | 0.01未満     | ---     | 0.01未満  | 0.01未満     | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | ---     | ---     | 0.005未満    | ---     | ---     | 0.005未満    | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | ---     | ---     | 0.010      | ---     | ---     | 0.010      | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | ---     | ---     | 3.6        | ---     | ---     | 4.6        | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | ---     | 0.001未満 | 0.001未満    | ---     | 0.001未満 | 0.001未満    | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 4.9     | 4.6     | 4.5        | 4.7     | 3.6     | 4.7        | --- | --- | --- | --- | --- |
| 39            | カルシウム, マグネシウム等(硬度)                 | 300mg/L以下     | mg/L | 1        | ---     | 12      | 12         | ---     | 15      | 17         | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | ---     | 32      | 47         | ---     | 35      | 43         | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | ---     | ---     | 0.02未満     | ---     | ---     | 0.02未満     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | ---     | 0.000001   | ---     | ---     | 0.000001   | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | ---     | ---     | 0.000001未満 | ---     | ---     | 0.000001未満 | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | ---     | ---     | 0.005未満    | ---     | ---     | 0.005未満    | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | ---     | ---     | 0.0005未満   | ---     | ---     | 0.0005未満   | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満   | 0.3未満   | 0.3未満      | 0.4     | 0.3未満   | 0.3未満      | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 6.6     | 6.6     | 6.6        | 6.5     | 6.5     | 6.6        | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | 異常なし       | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | 異常なし       | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満   | 0.5未満   | 0.5未満      | 0.5未満   | 0.5未満   | 0.5未満      | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満   | 0.1未満   | 0.1未満      | 0.1未満   | 0.1未満   | 0.1未満      | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.6     | 0.5     | 0.4        | 0.6     | 0.7     | 0.7        | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

|               |                                    |               |      |          |            |         |         |            |         |         |     |     |     |     |     |
|---------------|------------------------------------|---------------|------|----------|------------|---------|---------|------------|---------|---------|-----|-----|-----|-----|-----|
| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月7日     | 5月12日      | 6月16日   | 7月14日   | 8月4日       | 9月1日    | ---     | --- | --- | --- | --- | --- |
| (令和7年4月～9月分)  |                                    |               | 時刻   | 9:40     | 10:50      | 9:28    | 10:20   | 9:30       | 10:15   | ---     | --- | --- | --- | --- | --- |
| 名称 京北 山国地域    |                                    |               | 天候   | 晴後一時曇    | 曇後一時雨      | 曇時々晴    | 曇時々晴    | 曇後晴        | 晴       | ---     | --- | --- | --- | --- | --- |
| 場所 給水栓        |                                    |               | 気温   | 15.9     | 19.7       | 30.0    | 34.5    | 30.8       | 33.1    | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 13.7       | 19.6    | 23.1    | 30.4       | 32.3    | 32.1    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0       | 0       | 0          | 0       | ---     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出     | 不検出     | 不検出        | 不検出     | ---     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | 0.00005未満  | ---     | ---     | 0.00005未満  | ---     | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | 0.004未満    | ---     | ---     | 0.004未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 0.34       | ---     | ---     | 0.39       | ---     | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | 0.0004未満   | ---     | ---     | 0.0004未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.004      | 0.010   | 0.009   | 0.011      | 0.010   | 0.010   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.004      | 0.008   | 0.005   | 0.008      | 0.007   | 0.007   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001      | 0.001未満 | 0.001   | 0.003      | 0.003   | 0.003   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.008      | 0.014   | 0.015   | 0.021      | 0.021   | 0.020   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.004      | 0.009   | 0.007   | 0.007      | 0.006   | 0.006   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.003      | 0.004   | 0.005   | 0.007      | 0.008   | 0.007   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | 0.001未満 | 0.001未満 | 0.001未満    | 0.001未満 | 0.001未満 | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | 0.002未満    | ---     | ---     | 0.002未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | 0.002未満    | ---     | ---     | 0.003      | ---     | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満     | ---     | 0.01    | 0.02       | ---     | 0.02    | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.005未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | 0.002      | ---     | ---     | 0.006      | ---     | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | 4.3        | ---     | ---     | 4.8        | ---     | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | 0.001未満 | 0.001未満    | ---     | 0.001未満 | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 5.5        | 5.3     | 5.4     | 5.4        | 4.5     | 5.2     | --- | --- | --- | --- | --- |
| 39            | カルシウム, マグネシウム等(硬度)                 | 300mg/L以下     | mg/L | 1        | 18         | ---     | 20      | 24         | ---     | 24      | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 32         | ---     | 46      | 50         | ---     | 48      | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | 0.02未満     | ---     | ---     | 0.02未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.005未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | 0.0005未満   | ---     | ---     | 0.0005未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満      | 0.3     | 0.3未満   | 0.3未満      | 0.4     | 0.3未満   | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.3        | 6.9     | 6.9     | 6.9        | 7.0     | 7.0     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満      | 0.5未満   | 0.5未満   | 0.5未満      | 0.5未満   | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満      | 0.1未満   | 0.1未満   | 0.1未満      | 0.1未満   | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.8        | 0.6     | 0.4     | 0.7        | 0.7     | 0.6     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

| 令和7年度 水質試験結果書 |                                    |               | 日時   | 4月7日     | 5月12日      | 6月16日   | 7月14日   | 8月4日       | 9月1日    | ---     | --- | --- | --- | --- | --- |
|---------------|------------------------------------|---------------|------|----------|------------|---------|---------|------------|---------|---------|-----|-----|-----|-----|-----|
| (令和7年4月～9月分)  |                                    |               | 時刻   | 10:20    | 10:10      | 10:02   | 9:50    | 10:05      | 9:45    | ---     | --- | --- | --- | --- | --- |
| 名称            | 京北 細野地域                            |               | 天候   | 晴後一時曇    | 曇後一時雨      | 曇時々晴    | 曇時々晴    | 曇後晴        | 晴       | ---     | --- | --- | --- | --- | --- |
| 場所            | 給水栓                                |               | 気温   | 13.3     | 14.5       | 25.7    | 26.3    | 29.0       | 26.2    | ---     | --- | --- | --- | --- | --- |
| 番号            | 項目名                                | 基準値           | 単位   | 定量下限値/水温 | 12.1       | 17.8    | 21.2    | 27.9       | 29.9    | 28.1    | --- | --- | --- | --- | --- |
| 1             | 一般細菌                               | 100集落/mL以下    | 個/mL | 0        | 0          | 0       | 0       | 0          | 0       | ---     | --- | --- | --- | --- | --- |
| 2             | 大腸菌                                | 検出されないこと      |      |          | 不検出        | 不検出     | 不検出     | 不検出        | 不検出     | ---     | --- | --- | --- | --- | --- |
| 3             | カドミウム及びその化合物                       | 0.003mg/L以下   | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 4             | 水銀及びその化合物                          | 0.0005mg/L以下  | mg/L | 0.00005  | 0.00005未満  | ---     | ---     | 0.00005未満  | ---     | ---     | --- | --- | --- | --- | --- |
| 5             | セレン及びその化合物                         | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 6             | 鉛及びその化合物                           | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 7             | ヒ素及びその化合物                          | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 8             | 六価クロム化合物                           | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 9             | 亜硝酸態窒素                             | 0.04mg/L以下    | mg/L | 0.004    | 0.004未満    | ---     | ---     | 0.004未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 10            | シアン化物イオン及び塩化シアン                    | 0.01mg/L以下    | mg/L | 0.001    | 0.01未満     | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 11            | 硝酸態窒素及び亜硝酸態窒素                      | 10mg/L以下      | mg/L | 0.02     | 0.20       | ---     | ---     | 0.24       | ---     | ---     | --- | --- | --- | --- | --- |
| 12            | フッ素及びその化合物                         | 0.8mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 13            | ホウ素及びその化合物                         | 1.0mg/L以下     | mg/L | 0.05     | 0.05未満     | ---     | ---     | 0.05未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 14            | 四塩化炭素                              | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 15            | 1,4-ジオキサン                          | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 16            | シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | 0.04mg/L以下    | mg/L | 0.0004   | 0.0004未満   | ---     | ---     | 0.0004未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 17            | ジクロロメタン                            | 0.02mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 18            | テトラクロロエチレン                         | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 19            | トリクロロエチレン                          | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 20            | ベンゼン                               | 0.01mg/L以下    | mg/L | 0.0002   | 0.0002未満   | ---     | ---     | 0.0002未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 21            | 塩素酸                                | 0.6mg/L以下     | mg/L | 0.05     | 0.06       | 0.07    | 0.08    | 0.08       | 0.07    | 0.08    | --- | --- | --- | --- | --- |
| 22            | クロロ酢酸                              | 0.02mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001      | ---     | ---     | --- | --- | --- | --- | --- |
| 23            | クロロホルム                             | 0.06mg/L以下    | mg/L | 0.001    | 0.008      | 0.017   | 0.020   | 0.027      | 0.026   | 0.027   | --- | --- | --- | --- | --- |
| 24            | ジクロロ酢酸                             | 0.03mg/L以下    | mg/L | 0.001    | 0.006      | 0.010   | 0.011   | 0.013      | 0.014   | 0.014   | --- | --- | --- | --- | --- |
| 25            | ジブロモクロロメタン                         | 0.1mg/L以下     | mg/L | 0.001    | 0.001未満    | 0.001未満 | 0.001   | 0.002      | 0.002   | 0.002   | --- | --- | --- | --- | --- |
| 26            | 臭素酸                                | 0.01mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | ---     | 0.001未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 27            | 総トリハロメタン                           | 0.1mg/L以下     | mg/L | 0.004    | 0.012      | 0.022   | 0.027   | 0.037      | 0.037   | 0.038   | --- | --- | --- | --- | --- |
| 28            | トリクロロ酢酸                            | 0.03mg/L以下    | mg/L | 0.001    | 0.006      | 0.010   | 0.010   | 0.010      | 0.010   | 0.010   | --- | --- | --- | --- | --- |
| 29            | ブロモジクロロメタン                         | 0.03mg/L以下    | mg/L | 0.001    | 0.004      | 0.005   | 0.006   | 0.008      | 0.009   | 0.009   | --- | --- | --- | --- | --- |
| 30            | ブロモホルム                             | 0.09mg/L以下    | mg/L | 0.001    | 0.001未満    | 0.001未満 | 0.001未満 | 0.001未満    | 0.001未満 | 0.001未満 | --- | --- | --- | --- | --- |
| 31            | ホルムアルデヒド                           | 0.08mg/L以下    | mg/L | 0.002    | 0.002未満    | ---     | ---     | 0.002未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 32            | 亜鉛及びその化合物                          | 1.0mg/L以下     | mg/L | 0.002    | 0.012      | ---     | ---     | 0.026      | ---     | ---     | --- | --- | --- | --- | --- |
| 33            | アルミニウム及びその化合物                      | 0.2mg/L以下     | mg/L | 0.01     | 0.01未満     | ---     | 0.01未満  | 0.01未満     | ---     | 0.01未満  | --- | --- | --- | --- | --- |
| 34            | 鉄及びその化合物                           | 0.3mg/L以下     | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.006      | ---     | ---     | --- | --- | --- | --- | --- |
| 35            | 銅及びその化合物                           | 1.0mg/L以下     | mg/L | 0.001    | 0.004      | ---     | ---     | 0.008      | ---     | ---     | --- | --- | --- | --- | --- |
| 36            | ナトリウム及びその化合物                       | 200mg/L以下     | mg/L | 1        | 3.8        | ---     | ---     | 4.2        | ---     | ---     | --- | --- | --- | --- | --- |
| 37            | マンガン及びその化合物                        | 0.05mg/L以下    | mg/L | 0.001    | 0.001未満    | ---     | 0.001未満 | 0.001未満    | ---     | 0.001未満 | --- | --- | --- | --- | --- |
| 38            | 塩化物イオン                             | 200mg/L以下     | mg/L | 0.4      | 3.3        | 3.4     | 3.2     | 3.5        | 2.7     | 3.8     | --- | --- | --- | --- | --- |
| 39            | カルシウム、マグネシウム等(硬度)                  | 300mg/L以下     | mg/L | 1        | 22         | ---     | 25      | 24         | ---     | 24      | --- | --- | --- | --- | --- |
| 40            | 蒸発残留物                              | 500mg/L以下     | mg/L | 1        | 39         | ---     | 58      | 50         | ---     | 51      | --- | --- | --- | --- | --- |
| 41            | 陰イオン界面活性剤                          | 0.2mg/L以下     | mg/L | 0.02     | 0.02未満     | ---     | ---     | 0.02未満     | ---     | ---     | --- | --- | --- | --- | --- |
| 42            | ジェオスミン                             | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 43            | 2-メチルインボルネオール                      | 0.00001mg/L以下 | mg/L | 0.000001 | 0.000001未満 | ---     | ---     | 0.000001未満 | ---     | ---     | --- | --- | --- | --- | --- |
| 44            | 非イオン界面活性剤                          | 0.02mg/L以下    | mg/L | 0.005    | 0.005未満    | ---     | ---     | 0.005未満    | ---     | ---     | --- | --- | --- | --- | --- |
| 45            | フェノール類                             | 0.005mg/L以下   | mg/L | 0.0005   | 0.0005未満   | ---     | ---     | 0.0005未満   | ---     | ---     | --- | --- | --- | --- | --- |
| 46            | 有機物(全有機炭素(TOC)の量)                  | 3mg/L以下       | mg/L | 0.3      | 0.3未満      | 0.4     | 0.4     | 0.4        | 0.3     | 0.4     | --- | --- | --- | --- | --- |
| 47            | pH値                                | 5.8 以上 8.6 以下 |      |          | 7.3        | 7.4     | 7.3     | 7.3        | 7.4     | 7.4     | --- | --- | --- | --- | --- |
| 48            | 味                                  | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 49            | 臭気                                 | 異常でないこと       |      |          | 異常なし       | 異常なし    | 異常なし    | 異常なし       | 異常なし    | 異常なし    | --- | --- | --- | --- | --- |
| 50            | 色度                                 | 5度 以下         | 度    | 0.5      | 0.5未満      | 0.5未満   | 0.5未満   | 0.5未満      | 0.5未満   | 0.5未満   | --- | --- | --- | --- | --- |
| 51            | 濁度                                 | 2度 以下         | 度    | 0.1      | 0.1未満      | 0.1未満   | 0.1未満   | 0.1未満      | 0.1未満   | 0.1未満   | --- | --- | --- | --- | --- |
| 52            | 遊離残留塩素                             | 0.1mg/L以上     | mg/L | 0.1      | 0.6        | 0.6     | 0.3     | 0.4        | 0.6     | 0.5     | --- | --- | --- | --- | --- |

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値