

令和8年度 水質試験結果書			日時	4月13日	5月12日	6月22日	7月7日	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	10:40	10:50	10:45	10:40	---	---	---	---	---	---	---
名称 外畑地域			天候	曇時々晴	曇時々晴	曇時々雨	曇時々雨	---	---	---	---	---	---	---
場所 給水栓			気温	16.0	23.7	20.4	25.5	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値\水温	14.4	17.7	21.4	21.5	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---
2	大腸菌	検出されないこと		不検出	不検出	不検出	不検出		---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	0.00005未満	---	---	0.00005未満	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	0.75	---	---	0.53	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	0.05未満	---	---	0.06	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	0.0004未満	---	---	0.0004未満	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
20	ペルフルオロ(オクタンー1ースルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.0000004	0.000004未満	---	---	0.000004未満	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.09	---	---	0.05	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	0.001	---	---	0.001	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.019	0.019	0.026	0.036	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.010	0.009	0.006	0.010	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001	0.001未満	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.024	0.024	0.033	0.043	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.015	0.014	0.015	0.019	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.005	0.005	0.006	0.007	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001未満	0.001未満	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	0.003	---	---	0.003	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	---	0.01未満	0.01未満	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	0.002	---	---	0.003	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	4.6	---	---	4.2	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	---	0.001未満	0.001未満	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.0	3.8	3.9	3.9	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	37	---	31	28	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	55	---	63	54	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	0.02未満	---	---	0.02未満	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	0.0005未満	---	---	0.0005未満	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.6	0.5	0.6	0.7	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.7	7.6	7.7	7.7	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.6	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.6	0.5	0.7	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	10:40	9:50	10:55	10:40	---	---	---	---	---	---	---
名称 静原地域				天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---
場所 給水栓				気温	22.3	22.0	26.9	23.5	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	15.0	16.7	20.4	21.5	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	0.43	---	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.08	---	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004未満	---	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.003	---	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.002	0.004	0.007	0.007	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.006	---	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.009	---	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.02	0.02	---	0.03	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	4.2	---	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.1	3.6	3.6	3.7	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	21	20	---	16	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	46	47	---	42	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.2	7.2	7.3	7.0	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.7	0.7	0.6	0.7	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月13日	5月12日	6月22日	7月7日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	9:10	9:20	9:05	9:10	---	---	---	---	---	---	---
名称 水尾地域				天候	曇時々晴	曇時々晴	曇時々雨	曇時々雨	---	---	---	---	---	---	---
場所 給水栓				気温	15.2	19.9	20.4	21.5	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	17.0	20.5	23.9	23.0	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	0.00005未満	---	---	0.00005未満	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	0.13	---	---	0.11	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	0.0004未満	---	---	0.0004未満	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	0.000004未満	---	---	0.000004未満	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.001未満	---	---	0.004	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.001	---	---	0.004	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.001未満	---	---	0.002	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.004未満	---	---	0.009	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.001未満	---	---	0.002	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.001未満	---	---	0.003	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	0.002未満	---	---	0.003	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	---	0.01未満	0.01未満	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	0.001	---	---	0.002	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	6.5	---	---	5.8	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	---	0.001未満	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.6	4.9	4.9	5.0	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	84	---	61	52	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	117	---	104	95	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	0.02未満	---	---	0.02未満	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	0.0005未満	---	---	0.0005未満	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.0	6.9	7.0	7.0	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.5	0.6	0.7	0.7	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月13日	5月12日	6月22日	7月7日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	9:40	9:55	9:40	9:40	---	---	---	---	---	---	---
名称 岩陰地域				天候	曇時々晴	曇時々晴	曇時々雨	曇時々雨	---	---	---	---	---	---	---
場所 給水栓				気温	18.0	19.6	19.7	21.5	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	14.5	18.2	21.8	21.7	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	0.00005未満	---	---	0.00005未満	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	0.32	---	---	0.26	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	0.0004未満	---	---	0.0004未満	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	0.000004未満	---	---	0.000004未満	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.02	0.02	0.02	0.02	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	0.001	---	---	0.001	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	4.0	---	---	4.2	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	---	0.001未満	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.2	4.0	4.2	4.3	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	25	---	26	27	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	48	---	53	55	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	0.02未満	---	---	0.02未満	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	0.0005未満	---	---	0.0005未満	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.0	7.1	7.1	7.1	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.7	0.7	0.7	0.8	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月13日	5月12日	6月22日	7月7日	---	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	9:10	11:00	10:25	10:40	---	---	---	---	---	---	---	---
名称 中川地域				天候	曇時々晴	曇時々晴	曇時々雨	曇時々雨	---	---	---	---	---	---	---	---
場所 給水栓				気温	14.7	20.2	22.3	25.3	---	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	15.0	18.5	21.6	21.2	---	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	0.00005未満	---	---	0.00005未満	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	0.12	---	---	0.09	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	0.05未満	---	---	0.06	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	0.0004未満	---	---	0.0004未満	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	0.000004未満	---	---	0.000004未満	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.003	---	---	0.006	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.002	---	---	0.003	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.002	---	---	0.002	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.008	---	---	0.011	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.002	---	---	0.002	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.003	---	---	0.003	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	0.002	---	---	0.003	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.04	---	0.04	0.03	---	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	0.001	---	---	0.002	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	10.7	---	---	8.8	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	---	0.001未満	0.001未満	---	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	5.5	5.5	5.7	7.5	---	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	72	---	66	72	---	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	101	---	102	111	---	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	0.02未満	---	---	0.02未満	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	0.0005未満	---	---	0.0005未満	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.6	7.4	7.5	7.4	---	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.8	0.6	0.7	0.8	---	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月13日	5月12日	6月22日	7月7日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	9:30	10:35	10:08	10:20	---	---	---	---	---	---	---
名称 小野郷地域				天候	曇時々晴	曇時々晴	曇時々雨	曇時々雨	---	---	---	---	---	---	---
場所 給水栓				気温	16.4	19.7	20.9	24.2	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	15.1	19.0	23.2	22.5	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	0.00005未満	---	---	0.00005未満	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	0.001	---	---	0.001	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	0.05	---	---	0.06	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	0.05	---	---	0.09	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	0.0004未満	---	---	0.0004未満	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	0.000004未満	---	---	0.000004未満	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.001	0.001	0.003	0.003	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.001未満	0.001	0.002	0.002	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001	0.001	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.004未満	0.004未満	0.006	0.006	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.001未満	0.001	0.002	0.002	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001未満	0.001未満	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	0.002	---	---	0.003	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	---	0.01未満	0.01未満	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	0.001	---	---	0.002	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	8.2	---	---	8.2	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	---	0.001未満	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.2	4.1	4.1	4.1	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	71	---	67	64	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	111	---	114	115	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	0.02未満	---	---	0.02未満	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	0.0005未満	---	---	0.0005未満	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.5	7.5	7.5	7.5	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.7	0.6	0.5	0.5	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	9:00	9:15	10:25	8:55	---	---	---	---	---	---	---
名称 雲ヶ畑地域				天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---
場所 給水栓				気温	17.1	16.2	20.6	21.0	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	12.8	14.9	18.6	19.8	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	0.49	---	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.13	---	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004未満	---	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.003	---	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.006	---	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.04	0.04	0.04	0.03	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.006	---	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	12.1	---	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.2	3.9	4.0	4.2	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	50	49	---	50	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	95	92	---	95	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---	---
43	ジオクシン	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.5	7.5	7.5	7.2	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.5	0.6	0.6	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書			日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	9:30	10:15	11:15	10:20	---	---	---	---	---	---	---	---
名称 鞍馬・貴船地域			天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---	---
場所 給水栓			気温	18.2	22.0	28.4	21.8	---	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	15.4	17.5	20.5	21.8	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	---	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	0.20	---	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.07	---	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004未満	---	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.003	---	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	0.01未満	---	0.01未満	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	5.8	---	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.7	4.6	4.5	4.6	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	47	46	---	47	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	76	78	---	79	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.2	7.1	7.1	7.1	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.8	0.8	0.9	0.7	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	10:20	10:40	10:15	10:40	---	---	---	---	---	---	---
名称 久多地域				天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---
場所 給水栓				気温	22.2	23.0	21.4	21.7	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	14.4	17.2	19.6	20.5	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	0.15	---	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.06	---	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004未満	---	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.004	---	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.02	0.02	---	0.02	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	6.6	---	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.8	4.8	4.9	4.8	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	23	23	---	23	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	49	47	---	54	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	0.000001	---	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.4	7.4	7.3	7.2	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.7	0.7	0.7	0.8	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書			日時	4月6日	5月25日	6月23日	7月22日	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	10:50	9:45	11:45	10:20	---	---	---	---	---	---	---
名称	広河原・花脊地域		天候	晴後曇	晴	曇一時雨	晴一時曇	---	---	---	---	---	---	---
場所	給水栓		気温	19.0	23.6	20.6	27.0	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	12.3	19.1	21.2	26.3	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	---	0.00005未満	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	---	0.004未満	---	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	---	0.32	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	---	0.0004未満	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	---	0.000004未満	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.07	0.08	0.09	0.05	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	---	0.006	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	---	0.002未満	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	---	0.003	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	---	0.01	0.02	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	---	0.052	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	---	0.003	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	---	5.7	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	---	0.001未満	0.002	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	5.0	5.2	5.0	4.7	---	---	---	---	---	---
40	カルシウム、マグネシウム等 (硬度)	300mg/L以下	mg/L	1	---	14	16	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	---	40	44	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	---	0.02未満	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	---	0.000001未満	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	---	0.000001未満	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	---	0.005未満	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	---	0.0005未満	---	---	---	---	---	---	---
47	有機物 (全有機炭素 (TOC) の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.2	7.2	7.2	7.1	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.7	0.5未満	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1	0.1未満	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.6	0.6	0.7	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	10:05	11:00	11:55	9:50	---	---	---	---	---	---	---
名称 別所地域				天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---
場所 給水栓				気温	18.2	17.7	23.6	21.1	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	14.8	17.8	19.8	21.8	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	0.52	---	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004未満	---	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.03	0.03	0.01	0.01	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.006	---	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	17.5	---	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	14.2	14.1	14.4	14.8	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	51	50	---	53	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	115	114	---	119	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.1	7.1	7.1	7.0	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.7	0.8	0.7	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	9:30	9:40	9:25	9:50	---	---	---	---	---	---	---
名称	百井地域			天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---
場所	給水栓			気温	17.0	18.6	19.2	19.2	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	11.0	13.4	15.8	17.1	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	0.15	---	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.06	---	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004未満	---	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.016	---	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01	0.01	---	0.01	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	11.4	---	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	7.2	8.1	7.7	9.2	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	21	25	---	29	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	65	71	---	80	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---	---
43	ジオクシン	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			6.9	6.9	6.7	6.8	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.7	0.6	0.7	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書			日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	9:00	9:10	9:00	9:15	---	---	---	---	---	---	---
名称 大原第1地域			天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---
場所 給水栓			気温	19.6	17.1	24.3	21.4	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	13.9	16.2	19.0	19.2	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---
10	シアン化合物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	0.37	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.06	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004未満	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.12	0.08	0.13	0.05未満	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.003	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.006	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.003	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	0.01未満	---	0.01未満	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.007	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	3.1	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	5.9	4.6	4.6	3.9	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	21	18	---	16	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	44	43	---	41	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3	0.3未満	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.0	6.9	6.9	6.7	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.7	0.7	0.6	0.8	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月14日	5月11日	6月8日	7月6日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	8:45	8:50	8:45	8:50	---	---	---	---	---	---	---
名称 大原第2地域				天候	曇時々晴	晴	曇後時々雨	雨	---	---	---	---	---	---	---
場所 給水栓				気温	19.2	20.9	23.7	21.7	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	15.7	18.3	22.5	23.8	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	0.00005未満	---	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	0.002	---	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	1.0	1.9	1.9	2.9	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	0.08	---	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	0.0004未満	---	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	0.000004	---	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	0.0002未満	---	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	0.05未満	---	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	0.004未満	---	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	0.001	---	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	0.001未満	---	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	0.002未満	---	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	0.01未満	---	0.01未満	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	0.003	---	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	4.6	---	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	0.001未満	---	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	6.2	6.1	5.7	5.7	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	30	37	---	46	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	62	78	---	105	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	0.02未満	---	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	0.000001未満	---	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	0.005未満	---	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	0.0005未満	---	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			6.7	6.7	6.6	6.5	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.6	0.6	0.7	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書			日時	4月6日	5月25日	6月23日	7月22日	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	9:30	10:05	11:10	10:05	---	---	---	---	---	---	---
名称	京北 黒田地域		天候	晴後曇	晴	曇一時雨	晴一時曇	---	---	---	---	---	---	---
場所	給水栓		気温	18.7	27.0	22.2	30.7	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	14.7	22.5	23.7	30.5	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと		不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	---	0.00005未満	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	---	0.004未満	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	---	0.33	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	---	0.0004未満	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸) (別名PFOS) 及びペルフルオロオクタン酸 (別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	---	0.000004未満	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.17	0.11	0.10	0.06	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.017	0.034	0.010	0.011	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.012	0.018	0.004	0.006	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.001未満	0.001	0.002	0.003	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.022	0.042	0.017	0.021	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.018	0.026	0.006	0.006	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.005	0.007	0.005	0.007	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001未満	0.001未満	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	---	0.002未満	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	---	0.002未満	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	0.01未満	0.03	0.04	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	---	0.005未満	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	---	3.9	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	---	0.001未満	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	3.8	4.0	4.2	5.8	---	---	---	---	---	---
40	カルシウム、マグネシウム等 (硬度)	300mg/L以下	mg/L	1	---	20	19	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	---	44	45	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	---	0.02未満	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	---	0.000001未満	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	---	0.000001未満	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	---	0.005未満	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	---	0.0005未満	---	---	---	---	---	---	---
47	有機物 (全有機炭素 (TOC) の量)	3mg/L以下	mg/L	0.3	0.6	0.7	0.3	0.3	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.5	7.5	7.5	7.5	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5	0.6	0.5未満	0.5未満	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.5	0.4	0.8	0.7	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書			日時	4月6日	5月25日	6月23日	7月22日	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	10:10	10:50	10:00	9:30	---	---	---	---	---	---	---
名称	京北 弓削地域		天候	晴後曇	晴	曇一時雨	晴一時曇	---	---	---	---	---	---	---
場所	給水栓		気温	16.9	26.8	21.6	29.5	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	14.0	20.1	21.5	27.0	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---
2	大腸菌	検出されないこと		不検出	不検出	不検出	不検出	不検出	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	---	0.00005未満	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	---	0.004未満	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	---	0.27	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	---	0.0004未満	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	---	0.000004未満	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	---	0.009	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	---	0.005	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	---	0.001	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	---	0.014	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	---	0.006	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	---	0.004	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	---	0.002未満	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	---	0.004	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01	0.04	0.04	0.03	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	---	0.005未満	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	---	0.001	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	---	5.2	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	---	0.001未満	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	6.1	6.4	6.1	5.7	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	---	22	22	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	---	47	48	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	---	0.02未満	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	0.000001未満	0.000001未満	0.000001未満	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001	0.000001未満	0.000001未満	0.000001未満	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	---	0.005未満	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	---	0.0005未満	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.4	0.3未満	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.0	7.4	7.4	7.3	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.8	0.6	0.8	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書				日時	4月6日	5月25日	6月23日	7月22日	---	---	---	---	---	---	---
(令和8年4月～7月分)				時刻	9:50	10:20	10:50	9:48	---	---	---	---	---	---	---
名称 京北 小塩地域				天候	晴後曇	晴	曇一時雨	晴一時曇	---	---	---	---	---	---	---
場所 給水栓				気温	17.2	26.6	20.5	27.0	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	13.7	19.5	21.2	26.0	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	---	---	0.00005未満	---	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	---	---	0.004未満	---	---	---	---	---	---	---	---
10	シアニ化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	---	---	0.22	---	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	---	---	0.0004未満	---	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	---	---	0.000004未満	---	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	---	---	0.0002未満	---	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	---	---	0.05未満	---	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	---	---	0.003	---	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	---	---	0.007	---	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001未満	0.001未満	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	---	---	0.002	---	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	---	---	0.001未満	---	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	---	---	0.002未満	---	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	---	---	0.012	---	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	---	0.01未満	0.01未満	---	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	---	---	0.005未満	---	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	---	---	0.007	---	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	---	---	3.8	---	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	---	0.001未満	0.001未満	---	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	4.9	4.6	4.5	4.5	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	---	12	13	---	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	---	35	35	---	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	---	---	0.02未満	---	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	---	---	0.000001未満	---	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	---	---	0.000001未満	---	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	---	---	0.005未満	---	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	---	---	0.0005未満	---	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3未満	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			6.6	6.7	6.6	6.6	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.6	0.6	0.7	0.8	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書			日時	4月13日	5月12日	6月22日	7月7日	---	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	10:20	9:35	9:18	9:25	---	---	---	---	---	---	---	---
名称	京北 山国地域		天候	曇時々晴	曇時々晴	曇時々雨	曇時々雨	---	---	---	---	---	---	---	---
場所	給水栓		気温	23.1	22.2	23.4	24.2	---	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	17.0	21.4	25.7	24.5	---	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	---	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	0.00005未満	---	---	0.00005未満	---	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	0.38	---	---	0.37	---	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	0.0004未満	---	---	0.0004未満	---	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	0.000004未満	---	---	0.000004未満	---	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.006	0.007	0.008	0.011	---	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.005	0.005	0.004	0.006	---	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.001	0.001	0.002	0.002	---	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.010	0.012	0.015	0.018	---	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.005	0.005	0.005	0.008	---	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.003	0.004	0.005	0.005	---	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001未満	0.001未満	---	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	---	0.01	0.01	---	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	0.003	---	---	0.004	---	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	4.4	---	---	4.1	---	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	---	0.001未満	0.001未満	---	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	5.6	5.5	5.5	5.4	---	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	21	---	20	19	---	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	44	---	46	43	---	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	0.02未満	---	---	0.02未満	---	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	0.0005未満	---	---	0.0005未満	---	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.3未満	0.3未満	0.3未満	0.3	---	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			6.9	6.8	7.0	6.8	---	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.8	0.6	0.8	0.7	---	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値

令和8年度 水質試験結果書			日時	4月13日	5月12日	6月22日	7月7日	---	---	---	---	---	---	---
(令和8年4月～7月分)			時刻	9:50	10:10	9:55	10:00	---	---	---	---	---	---	---
名称 京北 細野地域			天候	曇時々晴	曇時々晴	曇時々雨	曇時々雨	---	---	---	---	---	---	---
場所 給水栓			気温	19.6	17.6	18.3	20.6	---	---	---	---	---	---	---
番号	項目名	基準値	単位	定量下限値/水温	15.3	18.4	22.6	22.2	---	---	---	---	---	---
1	一般細菌	100集落/mL以下	個/mL	0	0	0	0	---	---	---	---	---	---	---
2	大腸菌	検出されないこと			不検出	不検出	不検出	不検出	---	---	---	---	---	---
3	カドミウム及びその化合物	0.003mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
4	水銀及びその化合物	0.0005mg/L以下	mg/L	0.00005	0.00005未満	---	---	0.00005未満	---	---	---	---	---	---
5	セレン及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
6	鉛及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
7	ヒ素及びその化合物	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
8	六価クロム化合物	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
9	亜硝酸態窒素	0.04mg/L以下	mg/L	0.004	0.004未満	---	---	0.004未満	---	---	---	---	---	---
10	シアン化物イオン及び塩化シアン	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
11	硝酸態窒素及び亜硝酸態窒素	10mg/L以下	mg/L	0.02	0.21	---	---	0.30	---	---	---	---	---	---
12	フッ素及びその化合物	0.8mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---
13	ホウ素及びその化合物	1.0mg/L以下	mg/L	0.05	0.05未満	---	---	0.05未満	---	---	---	---	---	---
14	四塩化炭素	0.002mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
15	1,4-ジオキサン	0.05mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
16	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/L以下	mg/L	0.0004	0.0004未満	---	---	0.0004未満	---	---	---	---	---	---
17	ジクロロメタン	0.02mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
18	テトラクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
19	トリクロロエチレン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
20	ペルフルオロ(オクタン-1-スルホン酸)(別名PFOS)及びペルフルオロオクタン酸(別名PFOA)	0.00005mg/L以下	mg/L	0.000004	0.000004未満	---	---	0.000004未満	---	---	---	---	---	---
21	ベンゼン	0.01mg/L以下	mg/L	0.0002	0.0002未満	---	---	0.0002未満	---	---	---	---	---	---
22	塩素酸	0.6mg/L以下	mg/L	0.05	0.09	0.08	0.12	0.13	---	---	---	---	---	---
23	クロロ酢酸	0.02mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
24	クロロホルム	0.06mg/L以下	mg/L	0.001	0.013	0.015	0.020	0.019	---	---	---	---	---	---
25	ジクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.008	0.008	0.010	0.009	---	---	---	---	---	---
26	ジブロモクロロメタン	0.1mg/L以下	mg/L	0.001	0.001未満	0.001	0.001	0.001	---	---	---	---	---	---
27	臭素酸	0.01mg/L以下	mg/L	0.001	0.001未満	---	---	0.001未満	---	---	---	---	---	---
28	総トリハロメタン	0.1mg/L以下	mg/L	0.004	0.018	0.021	0.028	0.026	---	---	---	---	---	---
29	トリクロロ酢酸	0.03mg/L以下	mg/L	0.001	0.008	0.009	0.010	0.009	---	---	---	---	---	---
30	ブロモジクロロメタン	0.03mg/L以下	mg/L	0.001	0.005	0.005	0.007	0.006	---	---	---	---	---	---
31	ブロモホルム	0.09mg/L以下	mg/L	0.001	0.001未満	0.001未満	0.001未満	0.001未満	---	---	---	---	---	---
32	ホルムアルデヒド	0.08mg/L以下	mg/L	0.002	0.002未満	---	---	0.002未満	---	---	---	---	---	---
33	亜鉛及びその化合物	1.0mg/L以下	mg/L	0.002	0.016	---	---	0.023	---	---	---	---	---	---
34	アルミニウム及びその化合物	0.2mg/L以下	mg/L	0.01	0.01未満	---	0.01未満	0.01未満	---	---	---	---	---	---
35	鉄及びその化合物	0.3mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---
36	銅及びその化合物	1.0mg/L以下	mg/L	0.001	0.005	---	---	0.007	---	---	---	---	---	---
37	ナトリウム及びその化合物	200mg/L以下	mg/L	1	3.9	---	---	4.1	---	---	---	---	---	---
38	マンガン及びその化合物	0.05mg/L以下	mg/L	0.001	0.001未満	---	0.001未満	0.001未満	---	---	---	---	---	---
39	塩化物イオン	200mg/L以下	mg/L	0.4	3.4	3.2	3.6	3.3	---	---	---	---	---	---
40	カルシウム、マグネシウム等(硬度)	300mg/L以下	mg/L	1	25	---	21	26	---	---	---	---	---	---
41	蒸発残留物	500mg/L以下	mg/L	1	48	---	48	52	---	---	---	---	---	---
42	陰イオン界面活性剤	0.2mg/L以下	mg/L	0.02	0.02未満	---	---	0.02未満	---	---	---	---	---	---
43	ジェオスミン	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---
44	2-メチルインボルネオール	0.00001mg/L以下	mg/L	0.000001	0.000001未満	---	---	0.000001未満	---	---	---	---	---	---
45	非イオン界面活性剤	0.02mg/L以下	mg/L	0.005	0.005未満	---	---	0.005未満	---	---	---	---	---	---
46	フェノール類	0.005mg/L以下	mg/L	0.0005	0.0005未満	---	---	0.0005未満	---	---	---	---	---	---
47	有機物(全有機炭素(TOC)の量)	3mg/L以下	mg/L	0.3	0.4	0.4	0.3	0.4	---	---	---	---	---	---
48	pH値	5.8 以上 8.6 以下			7.4	7.4	7.4	7.4	---	---	---	---	---	---
49	味	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
50	臭気	異常でないこと			異常なし	異常なし	異常なし	異常なし	---	---	---	---	---	---
51	色度	5度 以下	度	0.5	0.5未満	0.5未満	0.5未満	0.5未満	---	---	---	---	---	---
52	濁度	2度 以下	度	0.1	0.1未満	0.1未満	0.1未満	0.1未満	---	---	---	---	---	---
53	遊離残留塩素	0.1mg/L以上	mg/L	0.1	0.5	0.7	0.7	0.8	---	---	---	---	---	---

注 上記水質検査項目は水質基準に適合

備考 定量下限値とは分析機器で測定できる検出限界値